



Outcomes and Features of the Inspection of Receiver Tubes (ITR) System for Improved O&M in Parabolic Trough Plants



Protermosolar 09/02/2018

Marcelino Sanchez

msanchez@cener.com



CENER

ADItch

NATIONAL RENEWABLE
ENERGY CENTRE

Table of contents

1 INTRODUCTION

2 METHOD

3 RESULTS

4 CONCLUSIONS

1. INTRODUCTION

INSPECTION OF RECEIVER TUBES ITR SYSTEM



- CSP (PT) plants after several years since their commissioning demand new operation and maintenance (O&M) developments.
- Particularly, the receiver tube's potential degradation over time is a truly challenge.



VACUUM LOSS



DEGRADATION




BREAKAGE

1. INTRODUCTION

INSPECTION OF RECEIVER TUBES ITR SYSTEM



- Current version of the ITR System's last developments, advanced features and the main outcomes for a real, complete solar field inspection in a commercial PT power plant.



- Plant operators can more easily develop and adopt improved O&M strategies, such as corrective and preventive actions in the solar field, and even predictive actions in case of periodic inspections.

2. METHOD

INSPECTION OF RECEIVER TUBES ITR SYSTEM



ITR SYSTEM MAIN FEATURES:

- Terrestrial Inspection Device (up to 15 km/h, 96 receivers per min)



2. METHOD

INSPECTION OF RECEIVER TUBES ITR SYSTEM

ITR SYSTEM MAIN FEATURES:

- Terrestrial Inspection Device




2. METHOD

INSPECTION OF RECEIVER TUBES ITR SYSTEM

ITR SYSTEM MAIN FEATURES:

➤ Integral Processing Software



2. METHOD

INSPECTION OF RECEIVER TUBES ITR SYSTEM



ITR SYSTEM OUTPUTS:


➤ Receiver Tubes Status Classification

- Non-seasonal data

$$\Delta T = (T_{glass\ meas} - T_{adjust*}) \text{ [}^{\circ}\text{C]}$$


* relative to the linear distribution of $T_{glass\ meas}$ for each whole half-loop

- Box-and-whisker plot
statistical analysis



Outliers or untypical values (by half-loop and by plant)

Category	Interval Limit
Green (Ok)	$\Delta T < Q3 + 1.5 \times IQR$
Orange (Regular)	$Q3 + 1.5 \times IQR < \Delta T < Q3 + 3 \times IQR$
Red (No Ok)	$Q3 + 3 \times IQR < \Delta T$



➡ Outliers identification and localization (Outliers Map)

2. METHOD



INSPECTION OF RECEIVER TUBES ITR SYSTEM



ITR SYSTEM OUTPUTS :

➤ Theoretical simulation (Model)

- A detailed one-dimensional object oriented heat transfer model was developed for the receiver tube. It is possible to determine Heat losses and power in nominal conditions.
- Validation comparing model simulations with experimental measurements on the testing bench of CENER using different tube manufacturers in nominal conditions.
- Absorber emissivity values resulting from heat losses tests and from specific measurements of the reflectivity at far IR wavelengths of absorber samples are assumed for modelization.



2. METHOD

INSPECTION OF RECEIVER TUBES ITR SYSTEM




ITR SYSTEM OUTPUTS :

➤ Receiver Tubes Power Indicator (PI)


$$PI = \frac{P_{estim} - P_{theo}}{P_{theo}} [\%]$$

P_{estim} – estimated power of the tube [W]
 P_{theo} – theoretical power at nominal conditions [W]
(vacuum nominal pressure condition)

➔ Tubes Power Indicator (Power Map)



➔ Relative Power of Tubes Plot (Relative power of tubes Vs the cumulative percentage of tubes)





3. RESULTS

INSPECTION OF RECEIVER TUBES ITR SYSTEM


INSPECTION DATA:

- First commercial service performed in 2017 (3 solar fields; 8,736 tubes*)

* the scope included all of the high temperature half-loops and some low temperature half-loops (SF2).

RECEIVER TUBES STATUS CLASSIFICATION:

- Box-and-whisker plot for half-loops inspected in each solar field.



3. RESULTS

INSPECTION OF RECEIVER TUBES ITR SYSTEM



RECEIVER TUBES STATUS CLASSIFICATION:

➤ Inspection Data and Classification Results.

Classification Results	SF 1	SF 2	SF 3	Total
Total of ORANGE outliers	8	18	19	45
% of the total of tubes inspected	0,3%	0,4%	0,9%	0,5%
Total of RED outliers (Broken glass)	0	3	3	6
Total of RED outliers (Correct glass)	7	4	11	22
Total of RED outliers	7	7	14	28
% of the total of tubes inspected.	0,3%	0,2%	0,7%	0,3%

Total number of outliers	15	25	33	73
Total % of the total of tubes insp.	0,6%	0,6%	1,6%	0,8%


3. RESULTS

INSPECTION OF RECEIVER TUBES ITR SYSTEM



RECEIVER TUBES STATUS CLASSIFICATION:

➤ Outliers Map for the Solar Field 2 (SF2)




3. RESULTS

INSPECTION OF RECEIVER TUBES ITR SYSTEM



RECEIVER TUBES POWER INDICATOR:

➤ Tubes Power Indicator Map for the Solar Field 2 (SF2)




3. RESULTS

INSPECTION OF RECEIVER TUBES ITR SYSTEM



RECEIVER TUBES POWER INDICATOR:

- Relative Power of tubes of the Solar Field 2 (SF2)



Average Relative Power of Tubes
Inspected per Solar Field

SF 1	SF 2	SF 3	Total
97%	98%	97%	97%

3. RESULTS

INSPECTION OF RECEIVER TUBES ITR SYSTEM



RECEIVER TUBES HISTORICAL PERFORMANCE DATABASE AVAILABLE :

Pantalla principal - ITR (Inspección de Tubos Receptores)

Archivo Edición Ayuda

Resultados: //cerv33/termica/5420-MedidaCaracterizacion/ITR/201508_Medidas_Alvarado/Camara_FLIR/C3 dia 2/68.seq

#	Tubo	Inicio	Fin	# frames	Fecha	Temp. medida (°C)	Pérdidas estimadas (W/m)	Temperatura teórica (°C)	Pérdidas teóricas (W/m)	Porcentaje Pérdidas (%)	Valoración
52	141	2160	2181	22	2015-08-26 10:07:17	63	223	69	174	28,27	Regular
53	140	2195	2216	22	2015-08-26 10:07:18	65	230	69	173	32,60	Regular
54	139	2229	2250	22	2015-08-26 10:07:18	61	209	69	173	21,17	Regular
55	138	2263	2285	23	2015-08-26 10:07:19	59	197	69	172	14,36	Normal
56	137	2298	2320	23	2015-08-26 10:07:20	60	204	69	172	18,53	Normal
57	136	2333	2355	23	2015-08-26 10:07:20	61	210	69	171	22,39	Regular
58	135	2369	2390	22	2015-08-26 10:07:21	72	273	69	171	59,78	Roto
59	134	2403	2425	23	2015-08-26 10:07:22	59	199	69	170	16,78	Normal
60	133	2438	2461	24	2015-08-26 10:07:23	60	207	69	170	21,59	Regular
61	132	2476	2496	21	2015-08-26 10:07:23	61	207	69	170	22,14	Regular
62	131	2510	2531	22	2015-08-26 10:07:24	59	197	68	169	16,32	Normal
63	130	2546	2566	21	2015-08-26 10:07:25	61	209	68	169	23,74	Regular
64	129	2579	2600	22	2015-08-26 10:07:25	57	190	68	168	12,83	Normal
65	128	2614	2636	23	2015-08-26 10:07:26	61	212	68	168	26,57	Regular
66	127	2649	2671	23	2015-08-26 10:07:27	58	193	68	167	15,08	Normal
67	126	2686	2706	21	2015-08-26 10:07:28	55	180	68	167	7,63	Normal
68	125	2721	2743	23	2015-08-26 10:07:28	56	184	68	166	10,31	Normal
69	124	2756	2779	24	2015-08-26 10:07:29	56	184	68	166	11,05	Normal
70	123	2792	2813	22	2015-08-26 10:07:30	43	114	68	165	-31,06	Normal
71	122	2828	2849	22	2015-08-26 10:07:30	48	139	68	165	-15,92	Normal
72	121	2864	2884	21	2015-08-26 10:07:31	47	136	68	165	-17,27	Normal
73	120	2909	2931	23	2015-08-26 10:07:32	49	144	68	164	-12,32	Normal
74	119	2945	2966	22	2015-08-26 10:07:33	50	150	68	164	-8,46	Normal
75	118	2981	3002	22	2015-08-26 10:07:33	49	143	67	163	-12,21	Normal

Datos de toma: Dirección de toma: En contra de circulación de fluido Semilazo: Segundo

Datos ambientales: Temp. Ambiente: 24,0 Velocidad Viento: 0,6 DNI: 821 Dirección viento: 0

Datos planta: Temp. entrada (°C): 320 Temp. salida (°C): 384

- Nº Tubos correctos: 58
- Nº Tubos regulares: 37
- Nº Tubos rotos: 1
- Total tubos: 96

- Promedio de pérdidas (%): 15,29

Recalcular pérdidas
Inicio
Guardar toma
Exportar datos

- Robustness and reliability of ITR methodology proven in Real Operating conditions
- Receiver performance & durability check along its operational live

4. CONCLUSIONS

INSPECTION OF RECEIVER TUBES ITR SYSTEM



- The assessment of the tubes status is based on a **robust procedure** of **glass cover measurement** from IR images.
- **Classification of outliers** based on contrasted statistical method allows to identify and locate the tubes with the worst behaviour in a detailed and traceable way.
- By the application of a validated model for the tubes heat losses characterization in nominal conditions, the **power indicator** is obtained for tubes at operation conditions at inspection time.
- Thanks to the ITR Inspection System, **improved O&M strategies**, such as corrective and preventive actions in the solar field, and even predictive actions in case of periodic inspections, can be adopted by plant operators.
- **Historical database available**, receiver performance & durability check along its operational live
- Nowadays supplied at **commercial scale**.



Thank you very much for your attention!!

Marcelino Sánchez
Alberto García de Jalón
agarciadejalon@cener.com

www.cener.com



CENER

ADItch

NATIONAL RENEWABLE
ENERGY CENTRE